

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016375  
DATE: 12/04/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Kleidco  
CODE: 2909-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Kleidco Yapi Sistemleri San. Ve Tic. A.S.</b> <b>Yenibosna Merkez, Mahallesi,</b> <b>Yalcin Kores CD 14 D1</b> <b>Bahcelievler/Istanbul, Turkiye 34197</b>	<b>Series "Spectral 90"</b> <b>Aluminum Outswing Terrace Door</b>  Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1219mm(48") H-2438mm(96") Panel: W-1178mm(46.38") H-2403mm(94.63") DLO: W-991mm(39") H-2216mm(87.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class AW-PG40 1219 x 2438 (48 x 96)-ATD</b> <b>Design Pressure: ±1920 Pa (±40 psf)</b> <b>Water Penetration Resistance Test Pressure: 575 Pa (12.00 psf)</b>

Product Tested By: Twining Consulting Inc. dba Radco  
Report No: 246061-4.R  
Expiration Date: **July 31, 2028**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "M.D.", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-09/30/2023