

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016376
DATE: 12/04/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Kleidco
CODE: 2909-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Kleidco Yapi Sistemleri San. Ve Tic. A.S. Yenibosna Merkez, Mahallesi, Yalcin Kores CD 14 D1 Bahcelievler/Istanbul, Turkiye 34197	Series "Unique Sliding Door" Aluminum Sliding Door Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-3137mm(123.50") H-2413mm(95") Panel: W-1578mm(62.13") H-2330mm(91.75") DLO: W-1378mm(54.25") H-2134mm(84")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class AW-PG40 3137 x 2413 (124 x 95)-SD Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 575 Pa (12.00 psf)

Product Tested By: Twining Consulting Inc. dba Radco
Report No: 246061-3.R
Expiration Date: **July 31, 2028**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD", is written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-09/30/2023